



## ADDENDUM NO. 5

**Addendum Date:** October 4, 2016

**Revised Bid Date:** October 13, 2016   **Original Bid Date:** September 29, 2016

**Engineer:**     BSP Engineers, Inc.  
                     15 West Central Ave.  
                     Temple, TX 76501  
                     (254) 774-9611

**Project:**        City of Copperas Cove Parks Maintenance Building

**Owner:**        City of Copperas Cove, Texas

**Bid No.:**        2016-19-54

**Item #1:**

The bid opening is hereby extended to 2:00 PM on Thursday, October 13, 2016.

**Item #2:**

\*\*\*DISREGARD ITEM #10 in Addendum No. 4\*\*\*

The canopy on the front face of the building shall be constructed as follows:

1. 3"x3"x1/4" painted square tubing for columns set in 12" dia.x36" deep concrete footings
2. 8" C channel spanning between the columns
3. 6" 20 ga. metal studs at 24" O.C. for rafters and joists
4. 7/8" 20 ga. furring channel on the joists at 16" O.C.
5. 12" 26 ga. metal flat panels for the soffit
6. 26 ga. R panels for the roof to match new building
7. Flash at existing building
8. Trim to match new building
9. Recessed downlights per electrical sheets